



हरिपुर्वा नगरपालिका

नगर कार्यपालिकाको कार्यालय

हरिपुर्वा, सर्लाही

मधेश प्रदेश, नेपाल



पत्र संख्या :- २०८१/०८२

चलानी नं.:-

क्याटलग सपिङ्ग विधिबाट जेनेरेटर खरिद गर्ने सम्बन्धि सूचना ।

प्रकाशित मिति:- २०८२/०२/०९

यस नगरपालिका अन्तरगत संचालित रहेको नगर अस्पताल, हरिपुर्वामा आवश्यक जेनेरेटर उपलब्ध गराउन इच्छुक इजाजत प्राप्त उत्पादक कम्पनी वा अधिकृत/आधिकारिक बिक्रेताहरूले कम्पनी / फर्म दर्ता, भ्याट दर्ता, एजेन्सी दर्ता प्रमाणपत्र, Letter Of Authorization, आ.व. २०८०/०८१ को मु.अ.कर आयकर चुक्ताको प्रमाण पत्र लगायतका कागजातहरूको प्रमाणित प्रतिलिपीहरू समावेश गरी उपलब्ध गराउने जेनेरेटरको आधिकारिक स्पेसिफिकेशन, मूल्य र सुविधा सहितको गुणस्तर विवरण (क्याटलग वा ब्रोसर) संलग्न राखी यो सूचना प्रकाशन भएको मितिले १० (दश) दिन (मिति २०८२/०२/१८ गते) भित्र यस कार्यालयको कार्यालय समयमा रितपूर्वक प्रस्ताव दर्ता गराउनुहुन सार्वजनिक खरिद नियमावली २०६४, को नियम ३१(ख) बमोजिम सम्बन्धित उत्पादक कम्पनी वा आधिकारिक बिक्रेताहरूको जानकारीको लागि यो सूचना प्रकाशन गरिएको छ। साथै उक्त प्रस्ताव ११ (एघार) औं दिनको ५:०० बजे यस कार्यालयमा खोलिएछ। विस्तृत स्पेसिफिकेशन लगायतका थप जानकारीका लागि कार्यालयमा सम्पर्क गर्न सकिने गराइन्छ।

Technical Specification For 62.5 KVA Diesel Generators

S.N.	CRITERIA	REQUIREMENT	OFFERED SPECIFICATION
1	General	The supply and installation of generator set is equipped with compact acoustic enclosure (CANOPY) type fuel efficient diesel engine with low vibration, having in-built AVR facility, Standard Panel and Controller with LCD/LED screen .	Make: Model: Country of Origin: Mfg. Year:
2	Engine	4 stroke, water cooled, diesel engine developing maximum rated output power not less than 80 HP (engine fully equipped with accessories) at the governed speed for full load operation. Shall be equipped with direct electric starting system with battery.	Make: Model: Power:
3	Phase	3 Phase	
4	Power Rating Tange (KVA)	Minimum 62.5 KVA (50 KW)	
5	Power Factor	Minimum 0.8	
6	Rated Voltage	415 V	
7	Rated Frequency	50 Hz	



हरिपुरवा नगरपालिका

नगर कार्यपालिकाको कार्यालय

हरिपुरवा, सर्लाही

मधेश प्रदेश, नेपाल

पत्र संख्या :- २०८१/०८२

चलानी नं.:-



8	Noise Level (ISO 3744)	Less than 75 db	
9	Oil Change	Mimimum 500 hours	
10	Fuel Tank Capacity	Minimum 150 liters	
11	Warranty	Manufacturer shall provide a minimum of two year warranty after acceptance.	
	Manuals	One copy of Owner's Instructions and Maintenance manual in English shall be supplied	
13	Essential Accessories	Suitable Power Cables (Approx 40 m), 100A change over, Earthing material and others Accessories required for installation and operation of DG set at site.	Cable Material:
14	Paint	Standard Colour	
15	Instructions	All signs and instructions in the equipment shall be in English.	
16	Delivery	The Generator set shall be delivered to: Haripurwa Municipality, Office of Municipal Executive, Haripurwa, Sarlahi	

प्रमुख प्रशासकिय अधिकृत

(Handwritten signature)